

701 South Texas Avenue  
Bryan, Texas 77803  
Voice - 979 775 6036  
Fax - 979 779 0727  
Email - [design@patarch.com](mailto:design@patarch.com)  
[www.patarch.com](http://www.patarch.com)

## ADDENDUM

### Return with the Drawings and Specifications


ADDENDUM NO. 2  
to the  
Drawings and Specifications  
for

BMI Defense Systems  
10350 State Hwy 30  
College Station TX

Project Number: 2009-2917

PATTERSON ☆ ARCHITECTS  
701 South Texas Avenue  
Bryan, Texas 77803

8/10/2010



#### 1.01 GENERAL

- A. This addendum, consisting of 1 page, supersedes the Drawings and Specifications dated July 26, 2010.
- B. The following changes, corrections, or additions are part of the Bid Documents.

#### 2.01 REFER TO ARCHITECTURAL DRAWINGS

- A. Sheet A-2.4
  1. Room Finish Schedule Building 'B':
    - a. Rooms 308, 311, & 315, delete the requirement for finish 'F1' for the floors, and substitute finish 'F8'.
    - b. Rooms 307, 308, 309, 311, & 401, add Note 6 to Remarks column.
    - c. Add the following Note 6 to Room Finish Schedule Notes:
      6. Exposed structural steel in these areas shall not be painted.
    - d. Room 315, paint exposed structural steel.

END OF ADDENDUM