



ADDENDUM NO. 1

Date: February 9, 2010
Project: Waste Water Treatment Plant Clarifier No. 2 Rehabilitation
Project No.: 080269571-A
Proposal Deadline: February 11, 2010; 2:00 PM

This Addendum is an amendment to extend the above Proposal Deadline to **February 23, 2010 at 2:00 PM**, and to the Bidding Documents for the named project and as such will be part of and included in the Contract Documents. ***Acknowledge receipt of this Addendum in the space provided on the Proposal. Failure to do so may subject the bidder to disqualification.***

Attachment:

Jones & Carter, Inc., "Addendum No. 1", dated January 28, 2010 (1 page)

ADDENDUM NO. ONE (1)
to the
CONTRACT DOCUMENTS, SPECIFICATIONS AND CONSTRUCTION DRAWINGS
for construction of
WASTEWATER TREATMENT PLANT CLARIFIER NO. 2 REHABILITATION
PPA# 080269571
for
TEXAS A & M UNIVERSITY
PHYSICAL PLANT
BRAZOS COUNTY, TEXAS

January 28, 2010

Addendum No. One (1) covers the following changes to the contract documents, technical specifications and construction drawings:

TECHNICAL SPECIFICATIONS

1. SPECIFICATION 09921- PROTECTIVE COATINGS


Delete paragraph 3.2 (c)(5). Silica abrasive blasting material may be used. Worker protection and compliance with applicable worker safety regulations are the responsibility of the Contractor.

CONSTRUCTION DRAWINGS

No changes to the construction drawings.

CLARIFICATIONS

1. The specified Chesterton concrete and steel coating products will be retained as the sole acceptable manufacturer for the specific project items as shown in the construction drawings.
2. Unit Price #1 shall include repairing and replacing any damaged grout in the existing launder trough at a slope to match the existing upon completion of replacement of the neoprene seal between sections of launder.



Jason A. Kirby, P.E.
Jones & Carter, Inc.
TBPE Firm No. F-439



END OF ADDENDUM NO. 1